

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Labor & Economic Growth
Bureau of Construction Codes & Fire Safety
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	The Michigan Department of Labor & Economic Growth will not discriminate against any individual or group because of race, sex, religion, age, national origin, color, marital status, disability, or political belief. If you need help with reading, writing, hearing, etc., under the Americans with Disabilities Act, you may make your needs known to this agency.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Redman Homes Inc 308 Sheridan Drive PO Box 95 Topeka, IN 46571	COMPLIANCE ASSURANCE PROGRAM NO.: 167
	BUILDING SYSTEM APPROVAL REPORT NO.: 40079
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: M 7032B / 7033B with Basement, Reverse Basement, Crawlspace, Reverse Crawlspace and Various Options			
USE GROUP: R3	CONSTRUCTIVE TYPE: VB	OCCUPANT LOAD: 6 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 57.8/ 86.6 PSF	FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 50/75 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 8 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 8356

APPLICABLE STATE CODES

Building – 2003 MRC/B	Electrical – 2003 MRC/E	Mechanical – 2003 MRC/M	Plumbing – 2003 MRC/P
------------------------------	--------------------------------	--------------------------------	------------------------------

LIMITATIONS OF APPROVAL (IF ANY):

HVAC equipment and duct work is subject to the approval of the local enforcing agency. The specific options and loads shall be identified for each unit manufactured.

CERTIFICATION

REVIEWED BY:

James M. Greene, Plan Reviewer

AGENCY OFFICIAL:

Irvin J. Poke, AIA, Chief, Plan Review Division

ISSUED DATE:

June 6, 2005

PUBLISHED DATE:

June 9, 2005

cc: PFS Corporation