

STATE OF MICHIGAN
BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

* * * * *

In the matter of the compliance submission of	)	
DTE ELECTRIC COMPANY concerning Emergency	)	
Electrical Procedures in Section C3 of its rate	)	Case No. U-22059
book for electric service.	)	
_____	)	

At the August 27, 2026 meeting of the Michigan Public Service Commission in Lansing,
Michigan.

PRESENT: Hon. Daniel C. Scripps, Chair
Hon. Katherine L. Peretick, Commissioner
Hon. Shaquila Myers, Commissioner

ORDER

On December 18, 2025, the Commission issued an order in Case No. U-21990 (December 18 order) approving a special contract between DTE Electric Company (DTE Electric) and Green Chile Ventures LLC (Customer). The December 18 order, in part, directed DTE Electric to update the company's Emergency Electrical Procedures in Section C3 of its rate book and any other relevant company procedures in such a way as to ensure that the Customer's load would be shed prior to other customers in the event of an emergency. December 18 order, pp. 41, 44-45.

On March 18, 2026, DTE Electric submitted an application for approval of the requested changes in this docket in line with the expectations set forth by the December 18 order. The changes made to the rate book amended company procedures such that customers that take service from DTE Electric after October 1, 2025, with capacity of at least 500 megawatts (MW) or customers that take service under the Large Load Provision of Rate Schedule No. D11, will now

be subject to firm load shedding prior to other customers, provided that such customer load shedding: (1) does not compromise system reliability and (2) can prevent shedding the firm load of other DTE Electric customers. The Commission Staff notes the added provisions add further protections to ensure that both the Customer in this case and any future significant new load from customers that exceeds the 500 MW threshold will not adversely impact the grid reliability experienced by other customers.

On April 16, 2026, the Michigan Department of Attorney General filed comments expressing concerns regarding the proposed changes to the Emergency Electrical Procedures. The Association of Businesses Advocating Tariff Equity (ABATE) also filed comments on May 19, 2026. ABATE claims that the proposed changes create an unreasonable and unnecessary burden on large load customers that was not intended by the December 18 order.

The Commission adopts DTE Electric's second proposed change to its Emergency Electrical Procedures, finding that this additional provision is warranted to reflect considerations relating to local reliability and that it does not make sense to shed load from any customer unless such load shedding is needed to serve a reliability purpose. For the same reason, the Commission does not adopt the company's first proposed change the Commission expects that DTE Electric will not shed the load of any customer that would compromise system reliability, making such a provision unnecessary. Thus, customers that take service from DTE Electric after October 1, 2025, with capacity of at least 500 MW or customers that take service under the Large Load Provision of Rate Schedule No. D11, will be subject to firm load shedding prior to other customers, provided that such customer load shedding can prevent shedding the firm load of other DTE Electric customers. The Commission further finds that these revisions to DTE Electric's Emergency Electrical Procedures in Section C3 of the company's rate book comply with the December 18 order and that

ex parte approval is appropriate because the request will not affect rates or rate schedules resulting in an increase in the cost of service to customers. *See*, MCL 460.6a(3).

THEREFORE, IT IS ORDERED that DTE Electric Company's update to the Emergency Electrical Procedures in Section C3 of the company's rate book as filed in the application are approved, as modified by this order.

The Commission reserves jurisdiction and may issue further orders as necessary.

Any party desiring to appeal this order must do so in the appropriate court within 30 days after issuance and notice of this order, pursuant to MCL 462.26. To comply with the Michigan Rules of Court's requirement to notify the Commission of an appeal, appellants shall send required notices to both the Commission's Executive Secretary and to the Commission's Legal Counsel.

Electronic notifications should be sent to the Executive Secretary at LARA-MPSC-Edockets@michigan.gov and to the Michigan Department of Attorney General - Public Service Division at sheacl@michigan.gov. In lieu of electronic submissions, paper copies of such notifications may be sent to the Executive Secretary and the Attorney General - Public Service Division at 7109 W. Saginaw Hwy., Lansing, MI 48917.

MICHIGAN PUBLIC SERVICE COMMISSION

Daniel C. Scripps, Chair

Katherine L. Peretick, Commissioner

Shaquila Myers, Commissioner

By its action of August 27, 2026.

Lisa Felice, Executive Secretary

PROOF OF SERVICE

STATE OF MICHIGAN)


Case No. U-22059

County of Ingham)

Brianna Brown being duly sworn, deposes and says that on August 27, 2026 A.D. she electronically notified the attached list of this **Commission Order via e-mail transmission**, to the persons as shown on the attached service list (Listserv Distribution List).


Brianna Brown

Subscribed and sworn to before me
this 27th day of August 2026.


Angela P. Sanderson
Notary Public, Shiawassee County, Michigan
As acting in Eaton County
My Commission Expires: May 21, 2030

Service List for Case: U-22059

Name	On Behalf Of	Email Address
DTE Electric Company Jon P. Christinidis	DTE Electric Company DTE Electric Company	mpscfilings_account@dteenergy.com jon.christinidis@dteenergy.com